

**§ 21.26. Ventilation in indoor housing facilities.**

Indoor housing facilities for dogs shall be sufficiently ventilated when dogs are present to minimize drafts, odors, ammonia levels and moisture condensation. Ventilation shall be provided by means of windows, doors, vents or air conditioners. Auxiliary ventilation from fans, blowers or air conditioners shall be provided when the ambient temperature is 85° F (29.5° C) or higher. The relative humidity shall be maintained at a level that ensures the health and well-being of the dog housed therein in accordance with generally accepted husbandry practices.

**Source**

The provisions of this § 21.26 amended January 12, 1996, effective April 12, 1996, 26 Pa.B. 161. Immediately preceding text appears at serial page (140186).

---

No part of the information on this site may be reproduced for profit or sold for profit.

This material has been drawn directly from the official Pennsylvania Code full text database. Due to the limitations of HTML or differences in display capabilities of different browsers, this version may differ slightly from the official printed version.

GrabzIt