

§ 28a.5. Ammonia levels.

(a) *Levels.* Ammonia levels in all areas and rooms of the kennel and kennel housing facility, where a dog is housed, kept or present, including primary enclosures may not be greater than 15 ppm (parts per million) except within 30 minutes of the completion of active sanitation of that primary enclosure.

(b) *Measurements.* Ammonia level measurements shall be taken at the level of the dogs.

Cross References

This section cited in 7 Pa. Code § 28a.2 (relating to ventilation).

No part of the information on this site may be reproduced for profit or sold for profit.

This material has been drawn directly from the official Pennsylvania Code full text database. Due to the limitations of HTML or differences in display capabilities of different browsers, this version may differ slightly from the official printed version.

Grabzt